



IES INDOOR REPORT

PHOTOMETRIC FILENAME : BS100LEDPLUS2HTLOWT50120-277V-FL_S.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TESTLAB] Photopia 2017.0.4 see: www.ltioptics.com/ies
 [ISSUEDATE]
 [TESTDATE] Fri Jun 30 09:04:43 2017
 [MANUFAC] BEGHELLI
 [LUMINAIRE] BS100LEDPLUS2HTLOWT50120-277V-FL
 [LAMP] LED 0.428W White 3030 package (150mA)
 [LAMPCAT] SPMWHT328FD5WAV0S0
 [OTHER] Indoor Photometric Report
 [OTHER] LUMINAIRE PROPERTIES
 [OTHER] Number of lamps: 96
 [OTHER] Lumens per lamp: 67.1
 [OTHER] Input watts: 50
 [OTHER] Distribution: Direct
 [OTHER] Symmetry: Quadrilateral
 [OTHER] Photometric Type: C
 [OTHER] Luminous shape: Rectangle
 [OTHER] Luminous dimensions (feet)
 [OTHER] 0 - 180 Axis: 2.3
 [OTHER] 90 - 270 Axis: 0.6
 [OTHER] Height: 0.3

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	6069
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	121
Total Luminaire Watts	50
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.22
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	2.28 ft
Luminous Width (90-270)	0.55 ft
Luminous Height	0.32 ft

IES INDOOR REPORT**PHOTOMETRIC FILENAME : BS100LEDPLUS2HTLOWT50120-277V-FL_S.IES****LUMINANCE DATA (cd/sq.m)**

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	14017	11021	11067
55	11683	9237	9284
65	8693	7126	7421
75	5667	4770	4968
85	3438	2481	2535

IES INDOOR REPORT
PHOTOMETRIC FILENAME : BS100LEDPLUS2HTLOWT50120-277V-FL_S.IES

CANDELA TABULATION

	0	15	30	45	60	75	90
0.0	2130.32	2130.32	2130.32	2130.32	2130.32	2130.32	2130.32
2.5	2126.81	2120.68	2137.57	2114.91	2116.66	2120.92	2129.64
5.0	2105.06	2109.19	2120.38	2121.64	2107.55	2115.48	2114.82
7.5	2103.13	2093.57	2104.02	2099.68	2096.19	2112.97	2102.62
10.0	2067.62	2085.17	2079.61	2087.08	2085.70	2081.54	2084.02
12.5	2052.01	2044.18	2045.11	2053.26	2056.46	2059.77	2057.64
15.0	2019.52	2014.72	2023.07	2023.48	2021.54	2024.40	2025.08
17.5	1980.15	1978.52	1980.18	1989.20	1989.39	1991.10	1988.59
20.0	1941.18	1942.00	1941.51	1952.70	1952.81	1959.70	1967.21
22.5	1896.33	1899.08	1901.17	1904.29	1917.36	1928.23	1930.03
25.0	1850.05	1848.47	1852.47	1857.26	1875.06	1880.02	1895.26
27.5	1803.06	1798.45	1798.90	1819.50	1829.99	1839.75	1842.92
30.0	1748.93	1744.95	1747.19	1762.89	1775.82	1793.98	1804.15
32.5	1679.57	1692.12	1692.11	1709.18	1723.90	1743.79	1752.95
35.0	1630.78	1626.43	1631.49	1649.45	1657.75	1685.52	1698.62
37.5	1554.71	1560.11	1562.05	1583.64	1603.91	1632.76	1646.91
40.0	1490.90	1490.80	1497.15	1513.90	1536.19	1568.65	1582.97
42.5	1410.25	1410.50	1425.56	1442.87	1467.12	1501.35	1513.53
45.0	1328.28	1331.03	1349.50	1376.76	1398.29	1426.89	1445.90
47.5	1239.70	1247.34	1274.57	1302.63	1327.21	1352.54	1374.08
50.0	1143.77	1155.50	1190.80	1221.51	1251.29	1275.38	1298.13
52.5	1043.25	1064.82	1104.20	1146.47	1176.43	1194.90	1215.52
55.0	944.86	968.58	1018.72	1069.77	1094.12	1112.00	1136.78
57.5	845.26	870.21	931.86	985.32	1013.61	1037.47	1057.56
60.0	744.76	777.38	844.91	901.86	934.24	956.38	977.45
62.5	647.72	680.41	757.47	817.98	855.31	878.71	903.45
65.0	560.99	588.02	669.52	735.31	773.64	798.61	820.28
67.5	474.40	505.21	583.79	654.85	691.91	718.06	740.63
70.0	391.19	427.39	502.58	572.08	611.78	636.03	648.57
72.5	324.96	354.67	426.58	492.59	533.85	548.47	562.87
75.0	261.98	291.60	356.00	417.03	451.38	463.46	473.21
77.5	205.97	235.83	290.58	346.19	370.81	382.24	388.21
80.0	161.35	186.49	233.05	277.80	300.93	307.10	314.17
82.5	123.20	144.71	180.68	220.83	239.92	244.79	248.63
85.0	91.17	109.22	139.90	171.22	187.99	192.43	195.41
87.5	66.45	81.54	106.92	132.53	146.81	151.45	152.94
90.0	45.90	60.01	80.79	102.08	113.80	116.15	118.47
92.5	30.88	43.51	61.73	78.35	86.80	89.10	90.06
95.0	22.45	31.97	48.19	60.64	67.25	69.34	70.44
97.5	17.23	24.72	37.19	47.10	53.41	55.60	55.87
100.0	14.34	19.64	29.65	37.49	42.25	44.73	45.04
102.5	12.36	15.76	23.56	29.54	34.23	36.30	37.31
105.0	10.45	13.72	19.41	24.42	28.41	30.76	31.34
107.5	9.48	11.73	16.16	19.76	23.33	26.09	26.61
110.0	8.01	10.05	13.04	15.83	18.93	21.87	22.50
112.5	7.45	8.94	10.60	12.54	15.53	18.40	18.65
115.0	6.35	7.41	8.78	10.21	12.43	15.33	16.13
117.5	5.85	6.40	6.95	7.92	10.12	12.15	13.22
120.0	5.08	5.37	5.66	6.14	8.03	10.22	10.43
122.5	4.29	4.27	4.14	4.51	6.07	7.50	8.21
125.0	3.60	3.63	3.01	3.32	4.80	5.98	6.45
127.5	2.94	3.03	2.51	2.32	3.30	4.69	5.09
130.0	2.23	2.05	1.76	1.52	2.44	3.31	3.88
132.5	1.80	1.61	1.26	0.92	1.72	2.34	2.38

IES INDOOR REPORT
PHOTOMETRIC FILENAME : BS100LEDPLUS2HTLOWT50120-277V-FL_S.IES

CANDELA TABULATION - (Cont.)

135.0	1.36	1.20	0.73	0.49	1.08	1.71	2.02
137.5	0.97	0.71	0.47	0.29	0.57	1.09	1.39
140.0	0.62	0.50	0.23	0.18	0.27	0.64	0.63
142.5	0.31	0.26	0.16	0.10	0.19	0.33	0.44
145.0	0.12	0.11	0.11	0.10	0.10	0.19	0.16
147.5	0.11	0.13	0.14	0.16	0.11	0.13	0.14
150.0	0.16	0.19	0.24	0.20	0.14	0.11	0.12
152.5	0.31	0.32	0.30	0.26	0.25	0.20	0.18
155.0	0.41	0.41	0.44	0.33	0.40	0.30	0.44
157.5	0.47	0.34	0.53	0.45	0.41	0.41	0.23
160.0	0.48	0.47	0.59	0.61	0.53	0.46	0.37
162.5	0.57	0.63	0.78	0.63	0.58	0.59	0.58
165.0	0.53	0.56	0.52	0.65	0.61	0.64	0.59
167.5	0.56	0.70	0.61	0.61	0.58	0.57	0.68
170.0	0.75	0.71	0.73	0.52	0.71	0.60	0.80
172.5	0.98	0.66	0.54	0.51	0.61	0.75	0.80
175.0	0.85	0.67	0.87	0.64	0.57	0.72	0.71
177.5	1.24	0.84	0.65	0.61	0.76	0.51	0.82
180.0	0.58	0.58	0.58	0.58	0.58	0.58	0.58

IES INDOOR REPORT
PHOTOMETRIC FILENAME : BS100LEDPLUS2HTLOWT50120-277V-FL_S.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	771.24	N.A.	12.70
0-30	1631.05	N.A.	26.90
0-40	2664.82	N.A.	43.90
0-60	4666.43	N.A.	76.90
0-80	5786.3	N.A.	95.30
0-90	5965.15	N.A.	98.30
10-90	5764.3	N.A.	95.00
20-40	1893.58	N.A.	31.20
20-50	2955.87	N.A.	48.70
40-70	2704.89	N.A.	44.60
60-80	1119.87	N.A.	18.50
70-80	416.59	N.A.	6.90
80-90	178.85	N.A.	2.90
90-110	87.72	N.A.	1.40
90-120	98.80	N.A.	1.60
90-130	102.84	N.A.	1.70
90-150	103.94	N.A.	1.70
90-180	104.33	N.A.	1.70
110-180	16.61	N.A.	0.30
0-180	6069.48	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY


Zone	Lumens
0-10	200.85
10-20	570.39
20-30	859.81
30-40	1033.77
40-50	1062.3
50-60	939.31
60-70	703.28
70-80	416.59
80-90	178.85
90-100	62.70
100-110	25.02
110-120	11.08
120-130	4.04
130-140	0.97
140-150	0.13
150-160	0.16
160-170	0.17
170-180	0.07

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	99	95	105	101	97	93	96	93	90	92	89	87	88	86	84	81
2	98	90	83	77	95	88	81	76	84	78	74	80	76	72	77	73	70	68
3	89	79	71	64	87	77	69	63	74	67	62	71	65	61	68	63	59	57
4	82	70	61	54	79	68	60	54	66	58	53	63	57	52	61	55	51	49
5	75	62	53	47	73	61	53	46	59	51	46	57	50	45	55	49	44	42
6	70	56	47	41	68	55	47	40	53	46	40	51	45	39	50	44	39	37
7	64	51	42	36	63	50	42	36	48	41	35	47	40	35	45	39	35	33
8	60	46	38	32	58	46	38	32	44	37	32	43	36	31	42	36	31	29
9	56	43	34	29	55	42	34	29	41	34	28	40	33	28	38	32	28	26
10	53	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	25	24

POLAR GRAPH



Maximum Candela = 2137.57 Located At Horizontal Angle = 30, Vertical Angle = 2.5
1 - Vertical Plane Through Horizontal Angles (30 - 210) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0)