

---

## INSTRUCTIONS

### IMPORTANT SAFEGUARDS

When using electrical equipment, basic safety precautions should always be followed including the following:

1. **READ AND FOLLOW ALL SAFETY INSTRUCTIONS**
2. Disconnect power before performing work on electrical equipment
3. Do not use outdoors
4. Do not let power cords touch hot surfaces and do not mount near gas or electric heaters.
5. Use caution when servicing batteries. Battery acid can cause burns to skin and eyes. If acid is spilled on skin or eyes, flush with fresh water and contact a physician immediately.
6. Equipment should be mounted in locations and at heights where unauthorized personnel will not readily subject it to tampering.
7. The use of accessory equipment not recommended by Beghelli USA, may cause an unsafe condition, and will void the unit's warranty.
8. Do not use this equipment for other than its intended purpose.
9. Servicing of this equipment should be performed by qualified service personnel.
10. CAUTION: Dispose of lamp with care. To avoid shattering: Do not use lamp in excess of rated voltage, protect lamp against abrasion, scratches and against liquids when lamp is operating. Do not store or place flammable materials near lamp.
11. **SAVE THESE INSTRUCTIONS!**

---

## INSTALLATION

(See Figure 1): LRP UNIT

1. Carefully unpack the unit from the box.
2. The fixture is supplied complete with canopy for wall or ceiling mount.
3. Extend unswitched supply of DC voltage to junction box (supplied by others) from terminals on charger board of battery unit (if applicable) or other supply of DC voltage of 6V, 12V or 24V.
4. Make positive and negative battery terminal connections inside junction box. Cap wire connections using wire nuts inside the junction box.
5. Secure the remote head using two screw hold slots on canopy. The two screw hole slots are designed to mate with standard style junction box.
6. Restore DC power to ensure operation of remote heads.

---

## MAINTENANCE

1. Clean lenses on a regular basis.  
NOTE: The servicing of any parts should be performed by qualified service personnel only. The use of replacement parts not furnished by Beghelli USA, may cause equipment failure and will void the warranty.

---

**Figure 1**

