

INSTRUCTIONS IMPORTANT SAFEGUARDS

When using electrical equipment, basic safety precautions should always be followed including the following:



1. **READ AND FOLLOW ALL SAFETY INSTRUCTIONS**
2. Do not use outdoors.
3. Equipment should be mounted in locations and at heights where unauthorized personnel will not readily subject it to tampering.
4. Do not mount near gas or electric heaters.
5. The use of accessory equipment is not recommended by Beghelli Inc., and may cause an unsafe condition, and will void the unit's warranty.

Do not use this equipment for other than its intended purpose.


Servicing of this equipment should be performed by qualified service personnel.

Disconnect AC power before servicing.

SAVE THESE INSTRUCTIONS!



FLEXIBLE CONDUIT ONLY



INSTALLATION

J-Box Mounting:

1. Feed fixture leads through main bottom case and connect AC power supply (Fig A).
2. Connect wires through J-Box. Main bottom case on J-Box and secure with screws.
3. Connect battery only after continuous AC power can be provided to the unit (Fig. B).
4. Align snaps and push housing directly onto main bottom case (Fig. C). Apply continuous AC power and press "TEST" button to check light.

NOTE: To appear outside blue sleeve of terminal before connecting.

Conduit:

1. Secure main bottom case to wall surface. Route wires through hole in conduit flange and make conduit connection.
2. Connect battery only after continuous AC power can be provided to the unit (Fig. B).
3. Align snaps and push housing directly onto main bottom case (Fig. C). Apply continuous AC power and press "TEST" button to check light.

WARNING: Unused wires must be capped using enclosed wire nuts.



Fig. A (J-Box)





Fig. B



Fig. C

Operation:

1. During an electrical power failure, the lamps will automatically come on for a minimum of 90 minutes.
2. To test, depress the "TEST" switch. The emergency lamps will illuminate. When the switch is released, the lamps will go off.

Wiring diagram: