

IES INDOOR REPORT

PHOTOMETRIC FILENAME : BS400LEDHTHOWT30120-277V_S.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TESTLAB] Photopia 2024.2.0 see: www.ltioptics.com/ies

[ISSUE DATE]

[TEST DATE] Tue Aug 26 09:06:19 2025

[TEST] 1

[MANUFAC]

[LUMCAT]

[LUMINAIRE] BS400LEDHTHOWT30120-277V_S

[LAMP] LED 6.09W 12" Fortimo 24 LED linear module (130mA)

[LAMPCAT] LED Strip 1ft 1100lm 840 NA LV4

[OTHER]

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	7986
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	133
Total Luminaire Watts	59.876
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.70
Spacing Criterion (90-270)	1.70
Spacing Criterion (Diagonal)	1.88
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	1.45 ft
Luminous Width (90-270)	1.45 ft
Luminous Height	0.27 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	8313	7805	8313
55	9503	8742	9503
65	10766	9627	10766
75	11771	10062	11771
85	12938	10093	12938

CANDELA TABULATION

	<u>0</u>
0	1206.15
5	1173.17
10	1188.54
15	1222.45
20	1262.26
25	1290.19
30	1324.95
35	1349.18
40	1358.94
45	1370.48
50	1376.76
55	1356.28
60	1321.19
65	1251.48
70	1146.14
75	1015.17
80	858.26
85	693.67
90	540.47
95	405.71
100	285.60
105	192.01
110	119.52
115	68.53
120	34.29
125	15.17
130	5.75
135	2.80
140	2.40
145	1.82
150	1.30
155	0.89
160	0.49
165	0.22
170	0.08
175	0.01
180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : BS400LEDHTHOWT30120-277V_S.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	460.72	N.A.	5.80
0-30	1059.38	N.A.	13.30
0-40	1904.99	N.A.	23.90
0-60	4178.63	N.A.	52.30
0-80	6477.35	N.A.	81.10
0-90	7236.97	N.A.	90.60
10-90	7124.04	N.A.	89.20
20-40	1444.27	N.A.	18.10
20-50	2504.76	N.A.	31.40
40-70	3506.15	N.A.	43.90
60-80	2298.72	N.A.	28.80
70-80	1066.21	N.A.	13.40
80-90	759.61	N.A.	9.50
90-110	656.14	N.A.	8.20
90-120	728.75	N.A.	9.10
90-130	744.73	N.A.	9.30
90-150	748.59	N.A.	9.40
90-180	749.09	N.A.	9.40
110-180	92.95	N.A.	1.20
0-180	7986.05	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	112.93
10-20	347.79
20-30	598.65
30-40	845.61
40-50	1060.49
50-60	1213.14
60-70	1232.51
70-80	1066.21
80-90	759.61
90-100	446.92
100-110	209.22
110-120	72.61
120-130	15.98
130-140	2.69
140-150	1.16
150-160	0.42
160-170	0.08
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : BS400LEDHTHOWT30120-277V_S.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	117	117	117	117	113	113	113	113	106	106	106	99	99	99	93	93	93	91
1	102	95	89	83	98	92	86	81	85	81	77	80	76	73	75	72	69	66
2	90	80	71	63	86	77	69	62	71	65	59	67	61	56	62	57	53	50
3	81	68	58	50	77	66	56	49	61	53	47	57	50	45	53	47	43	40
4	73	59	49	41	70	57	47	40	53	45	38	49	42	37	46	40	35	32
5	67	52	41	34	64	50	40	33	47	38	32	44	36	31	41	34	29	27
6	61	46	36	29	58	44	35	28	42	33	27	39	32	26	36	30	25	22
7	56	41	31	25	54	40	31	24	37	29	23	35	28	22	33	26	22	19
8	52	37	28	21	50	36	27	21	34	26	20	32	25	20	30	24	19	17
9	48	34	25	19	46	33	24	19	31	23	18	29	22	17	27	21	17	15
10	45	31	23	17	43	30	22	17	28	21	16	27	20	16	25	19	15	13


IES INDOOR REPORT
PHOTOMETRIC FILENAME : BS400LEDHTHOWT30120-277V_S.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	19.4	21.0	19.9	21.5	22.1	19.4	21.0	19.9	21.5	22.1
	3H	22.1	23.7	22.6	24.2	24.7	22.1	23.7	22.6	24.2	24.7
	4H	23.4	24.8	23.9	25.4	25.9	23.4	24.8	23.9	25.4	25.9
	6H	24.5	25.9	25.1	26.4	27.0	24.5	25.9	25.1	26.4	27.0
	8H	25.1	26.4	25.6	26.9	27.5	25.1	26.4	25.6	26.9	27.5
	12H	25.6	26.8	26.1	27.4	28.0	25.6	26.8	26.1	27.4	28.0
4H	2H	20.2	21.7	20.8	22.2	22.8	20.2	21.7	20.8	22.2	22.8
	3H	23.2	24.5	23.7	25.0	25.6	23.2	24.5	23.7	25.0	25.6
	4H	24.6	25.8	25.1	26.3	26.9	24.6	25.8	25.1	26.3	26.9
	6H	25.9	26.9	26.4	27.5	28.2	25.9	26.9	26.4	27.5	28.2
	8H	26.5	27.5	27.1	28.1	28.7	26.5	27.5	27.1	28.1	28.7
	12H	27.1	28.0	27.7	28.6	29.3	27.1	28.0	27.7	28.6	29.3
8H	4H	25.1	26.1	25.7	26.7	27.3	25.1	26.1	25.7	26.7	27.3
	6H	26.6	27.5	27.2	28.1	28.7	26.6	27.5	27.2	28.1	28.7
	8H	27.3	28.1	28.0	28.7	29.4	27.3	28.1	28.0	28.7	29.4
	12H	28.1	28.8	28.7	29.4	30.1	28.1	28.8	28.7	29.4	30.1
12H	4H	25.2	26.1	25.8	26.7	27.4	25.2	26.1	25.8	26.7	27.4
	6H	26.8	27.6	27.4	28.2	28.9	26.8	27.6	27.4	28.2	28.9
	8H	27.6	28.3	28.2	28.9	29.6	27.6	28.3	28.2	28.9	29.6

Maximum UGR = 30.1

POLAR GRAPH



Maximum Candela = 1376.76 Located At Horizontal Angle = 0, Vertical Angle = 50

1 - Vertical Plane Through Horizontal Angles (0 - 180)

2 - Horizontal Cone Through Vertical Angle (50) (Through Max. Cd.)