



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : SCALED2HTHOWT30120-277V\_S.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002  
 [TESTLAB] Photopia 2020.1.0 see: [www.ltioptics.com/ies](http://www.ltioptics.com/ies)  
 [ISSUEDATE]  
 [TESTDATE] Mon Apr 12 11:00:07 2021  
 [TEST] 1  
 [MANUFAC] BEGHE  
 [LUMCAT]  
 [LUMINAIRE] SCALED2HTHOWT30120-277V\_S  
 [LAMP] LED 0.915W DURIS S5 (150mA)  
 [LAMPCAT] GW PSLRS1.PC-LRLT-5L7N-1  
 [OTHER]

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	6464
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	129
Total Luminaire Watts	50
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	2.28 ft
Luminous Width (90-270)	0.55 ft
Luminous Height	0.32 ft

### LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	15317	11619	11109
55	13979	9762	9232
65	12124	7582	7078
75	9728	5144	4721
85	7086	2723	2438

IES INDOOR REPORT  
PHOTOMETRIC FILENAME : SCALED2HTHOWT30120-277V\_S.IES

CANDELA TABULATION

	<u>0</u>
0.0	2182.61
2.5	2188.17
5.0	2143.27
7.5	2144.45
10.0	2109.80
12.5	2100.49
15.0	2069.15
17.5	2038.44
20.0	2003.51
22.5	1972.43
25.0	1922.23
27.5	1873.99
30.0	1826.60
32.5	1773.24
35.0	1723.28
37.5	1658.93
40.0	1596.50
42.5	1528.99
45.0	1451.38
47.5	1383.23
50.0	1303.63
52.5	1219.41
55.0	1130.51
57.5	1045.51
60.0	952.85
62.5	868.89
65.0	782.37
67.5	695.81
70.0	608.05
72.5	528.05
75.0	449.67
77.5	370.22
80.0	299.71
82.5	238.82
85.0	187.90
87.5	143.44
90.0	109.48
92.5	80.98
95.0	62.28
97.5	49.36
100.0	38.13
102.5	30.86
105.0	25.42
107.5	21.24
110.0	17.56
112.5	14.09
115.0	11.51
117.5	9.88
120.0	8.00
122.5	6.64
125.0	4.82
127.5	3.45
130.0	2.62
132.5	1.98

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : SCALED2HTHOWT30120-277V\_S.IES**

**CANDELA TABULATION - (Cont.)**

<b>135.0</b>	1.43
<b>137.5</b>	0.69
<b>140.0</b>	0.49
<b>142.5</b>	0.17
<b>145.0</b>	0.22
<b>147.5</b>	0.12
<b>150.0</b>	0.14
<b>152.5</b>	0.25
<b>155.0</b>	0.49
<b>157.5</b>	0.42
<b>160.0</b>	0.44
<b>162.5</b>	0.69
<b>165.0</b>	0.74
<b>167.5</b>	0.73
<b>170.0</b>	0.58
<b>172.5</b>	0.82
<b>175.0</b>	0.82
<b>177.5</b>	1.02
<b>180.0</b>	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : SCALED2HTHOWT30120-277V\_S.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	788.64	N.A.	12.20
0-30	1675.27	N.A.	25.90
0-40	2750.92	N.A.	42.60
0-60	4885.05	N.A.	75.60
0-80	6134.31	N.A.	94.90
0-90	6345.38	N.A.	98.20
10-90	6140.8	N.A.	95.00
20-40	1962.28	N.A.	30.40
20-50	3084.78	N.A.	47.70
40-70	2908.05	N.A.	45.00
60-80	1249.26	N.A.	19.30
70-80	475.34	N.A.	7.40
80-90	211.07	N.A.	3.30
90-110	100.70	N.A.	1.60
90-120	112.73	N.A.	1.70
90-130	117.32	N.A.	1.80
90-150	118.57	N.A.	1.80
90-180	118.99	N.A.	1.80
110-180	18.29	N.A.	0.30
0-180	6464.38	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	204.59
10-20	584.06
20-30	886.63
30-40	1075.65
40-50	1122.5
50-60	1011.62
60-70	773.93
70-80	475.34
80-90	211.07
90-100	72.76
100-110	27.94
110-120	12.03
120-130	4.58
130-140	1.12
140-150	0.13
150-160	0.16
160-170	0.19
170-180	0.07

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : SCALED2HTHOWT30120-277V\_S.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	100	100	100	98
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83	81
2	98	89	82	76	95	87	81	75	83	78	73	80	75	71	76	73	69	67
3	89	78	70	63	86	76	69	62	73	66	61	70	64	60	67	63	58	56
4	81	69	60	53	79	68	59	53	65	58	52	62	56	51	60	55	50	48
5	75	62	53	46	72	60	52	45	58	51	45	56	49	44	54	48	43	41
6	69	55	46	40	67	54	46	40	52	45	39	51	44	39	49	43	38	36
7	64	50	41	35	62	49	41	35	48	40	35	46	39	34	44	38	34	32
8	59	46	37	31	58	45	37	31	44	36	31	42	35	31	41	35	30	28
9	56	42	34	28	54	41	33	28	40	33	28	39	32	28	38	32	27	25
10	52	39	31	25	51	38	31	25	37	30	25	36	30	25	35	29	25	23


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : SCALED2HTHOWT30120-277V\_S.IES**

**UGR TABLE - CORRECTED**

Reflectances											
Ceiling Cavity	70	70	50	50	30	70	70	50	50	30	
Walls	50	30	50	30	30	50	30	50	30	30	
Floor Cavity	20	20	20	20	20	20	20	20	20	20	
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	20.4	22.0	20.8	22.3	22.7	20.4	22.0	20.8	22.3	22.7
	3H	22.1	23.6	22.5	23.9	24.3	22.1	23.6	22.5	23.9	24.3
	4H	22.7	24.1	23.2	24.5	24.9	22.7	24.1	23.2	24.5	24.9
	6H	23.2	24.5	23.7	24.9	25.4	23.2	24.5	23.7	24.9	25.4
	8H	23.4	24.7	23.9	25.1	25.5	23.4	24.7	23.9	25.1	25.5
	12H	23.6	24.8	24.0	25.2	25.7	23.6	24.8	24.0	25.2	25.7
4H	2H	20.8	22.2	21.2	22.6	23.0	20.8	22.2	21.2	22.6	23.0
	3H	22.7	23.9	23.1	24.3	24.7	22.7	23.9	23.1	24.3	24.7
	4H	23.5	24.5	23.9	25.0	25.5	23.5	24.5	23.9	25.0	25.5
	6H	24.1	25.0	24.6	25.5	26.0	24.1	25.0	24.6	25.5	26.0
	8H	24.3	25.2	24.8	25.7	26.2	24.3	25.2	24.8	25.7	26.2
	12H	24.5	25.3	25.0	25.8	26.4	24.5	25.3	25.0	25.8	26.4
8H	4H	23.6	24.5	24.1	25.0	25.5	23.6	24.5	24.1	25.0	25.5
	6H	24.4	25.1	24.9	25.6	26.1	24.4	25.1	24.9	25.6	26.1
	8H	24.7	25.3	25.2	25.9	26.4	24.7	25.3	25.2	25.9	26.4
	12H	25.0	25.5	25.5	26.1	26.7	25.0	25.5	25.5	26.1	26.7
12H	4H	23.6	24.4	24.2	25.0	25.5	23.6	24.4	24.2	25.0	25.5
	6H	24.4	25.1	25.0	25.6	26.1	24.4	25.1	25.0	25.6	26.1
	8H	24.7	25.3	25.3	25.8	26.4	24.7	25.3	25.3	25.8	26.4

Maximum UGR = 26.7

POLAR GRAPH



Maximum Candela = 2188.17 Located At Horizontal Angle = 0, Vertical Angle = 2.5  
# 1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (0)